

Approval Number 2110513
Test Report: J-00390660



Water Regulations Approval Scheme Ltd.
Unit 13,
Willow Road,
Pen y Fan Industrial Estate,
Crumlin,
Gwent,
NP11 4EG

8th October 2021

Frenzelit GmbH
Frankenhammer,
95460 Bad Berneck,
Germany

**WATER REGULATIONS APPROVAL SCHEME LTD. (WRAS)
MATERIAL APPROVAL**

The material referred to in this letter is suitable for contact with wholesome water for domestic purposes having met the requirements of BS6920-1:2000 and/or 2014 'Suitability of non-metallic products for use in contact with water intended for human consumption with regard to their effect on the quality of the water'.

The reference relates solely to its effect on the quality of the water with which it may come into contact and does not signify the approval of its mechanical or physical properties for any use.

FIBRE

5075

`Novapress 260`.

Green coloured, compressed fibre material (bound with NBR), manufactured by calendaring.
For use with water up to 85°C.

For use only as a jointing/gasket material having been tested at a reduced surface area to volume ratio.

APPROVAL NUMBER: 2110513
APPROVAL HOLDER: FRENZELIT GMBH

The Scheme reserves the right to review approval.
Approval 2110513 is valid between October 2021 and October 2026

An entry, as above, will accordingly be included in the Water Fittings Directory on-line under the section headed, "Materials which have passed full tests of effect on water quality".

The Directory may be found at: www.wrasapprovals.co.uk/approvals-directory/

Yours Faithfully

A handwritten signature in blue ink, appearing to read 'Ian Hughes', with a stylized flourish at the end.

Ian Hughes
WRAS Approvals Manager