

Confirmation

drinking water hygienic suitability in accordance with KTW-BWGL - Annex D (edition: 07.03.2022)

Material:	novapress® 850
Range of application:	Components of equipment items with a surface area in contact with water < 10% in the equipment item (P2)
Risk group:	P2 (includes P3) – based on type testing
Operating temperature:	Cold - and Hot Water (23°C and 85°C)
Test report:	KTW-BWGL -Technologiezentrum Wasser - Karlsruhe Test report no. 5-0618/24 T02 from 02.12.2024 DIN EN 16421 (former W270) - Hygiene Institut - Gelsenkirchen Test report no. W-396392-24-Alb/Krü from 09.12.2024

We hereby confirm compliance with the requirements in accordance with the KTW BWGL - Annex D for components of equipment with a surface area in contact with water < 10 % for the cold and hot water range (23°C and 85°C).

The confirmation of conformity is valid up to 02 December 2029.

Bad Berneck, 12.12.2024



i.V. Dipl.-Ing. Andreas Will
- Manager R&D Industry -



i.A. Dr. Ing. Andreas Mierzwa
- Application Engineer -