


Hygiene-Institut des Ruhrgebiets

Institut für Umwelthygiene und Toxikologie

Direktor: Prof. Dr.rer.nat. Lothar Dunemann

Träger: Verein zur Bekämpfung der Volkskrankheiten im Ruhrkohlengebiet e.V.



Hygiene-Institut · Postfach 10 12 55 · 45812 Gelsenkirchen

Frenzelit-Werke GmbH
Frankenhammer 7
95460 Bad Berneck

Visitors/ postal address:

Rotthäuser Str. 21, 45879 Gelsenkirchen,
Germany

Switchboard (0049209) 9242-0
Phone (0049209) 9242-230
Fax (0049209) 9242-222
E-Mail c.schell@hyg.de
Internet www.hyg.de

Reference: W-279392e-16-SI/Ni
Contact person: Mrs. Dr. Ch. Schell

Gelsenkirchen, 21.12.2016

TEST CERTIFICATE

Enhancement of Microbial Growth on Materials to Come into Contact with Drinking water
Test pursuant to DVGW Technical Standard W 270, November 2007

Client: Frenzelit-Werke GmbH
Frankenhammer 7
95460 Bad Berneck

Test material: novapress® BASIC

Test method: Material test

According to test report **W-279392-16-SI/Ni** of **21.12.2016**, the material **novapress® BASIC** is conform to the requirements for the use in the area of drinking water systems pursuant to DVGW Technical Standard W 270 for sealings, joints and gaskets with larger surface etc. (D1) and sealings, joints and gaskets with smaller surface etc. (D2). Details regarding testing procedure and test results are itemized in the test report.

This test certificate is valid from the date of issue and, given that the conditions and requirements remain unaltered, expires on **21.12.2021**. Upon request of the client, the validity may be extended up to **31.12.2021** provided that the specifications of Technical Standard W 270 are met.

The Director of the Institute

p.p.

Dr. Ch. Schell

Head of Laboratory

Department of Water Hygiene and Environmental Microbiology



The test results and assessments refer exclusively to the examined test specimens and all applicable statutory regulations. The validity of the document expires in case of modifications in the composition of the material or the processing conditions. This present document may only be published and reproduced unabridged and unaltered. This document is no DVGW certification.

Träger: Verein zur Bekämpfung der Volkskrankheiten im Ruhrkohlengebiet e.V., Vereinsregister: **VR 519** Amtsgericht Gelsenkirchen, USt.-ID: **DE125018356**
Vorstand: Prof. Dr. Werner Schlake (Vors.), Prof. Dr. Jürgen Kretschmann, Dr. Emanuel Grün, Dr. Dirk Waider, Prof. Dr. Lothar Dunemann (geschäftsführ. Vorstand)