



CERT

DIN-DVGW type examination certificate

DIN-DVGW-Baumusterprüfzertifikat

NG-5118BQ0232

Registration Number
Registriernummer

Field of Application <i>Anwendungsbereich</i>	products of gas supply <i>Produkte der Gasversorgung</i>
Owner of Certificate <i>Zertifikatinhaber</i>	Frenzelit GmbH Frankenhammer 7, D-95460 Bad Berneck
Distributor <i>Vertreiber</i>	Frenzelit GmbH Frankenhammer 7, D-95460 Bad Berneck
Product Category <i>Produktart</i>	greasing and sealing materials: Sealing material for HTB resistant seals in the gas installation (5118)
Product Description <i>Produktbezeichnung</i>	flat sealing material on synthetic fiber basis with higher thermal resistance
Model <i>Modell</i>	novatec® PREMIUM XP
Test Reports <i>Prüfberichte</i>	type testing: 21-00137 from 12.04.2021 (EBI)
Test Basis <i>Prüfgrundlagen</i>	DIN 30653 (01.08.2018)

Date of Expiry / File No. 08.06.2025 / 21-0235-GNV
Ablaufdatum / Aktenzeichen

06.05.2021 Rie A-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle



Deutsche
Akkreditierungsstelle
D-ZE-16028-01-05

DVGW CERT GmbH
Zertifizierungsstelle

Josef-Wirmer-Str. 1-3
53123 Bonn

Tel. +49 228 91 88 - 888

Fax +49 228 91 88 - 993

www.dvgw-cert.com

info@dvgw-cert.com

Type <i>Typ</i>	Technical Data <i>Technische Daten</i>	Remarks <i>Bemerkungen</i>
novatec® PREMIUM XP	max. operating pressure: 1 bar	

certified Components
zertifizierte Bauteile / Werkstoffe

Registr. No. <i>Registrier-Nr.</i>	Component <i>Bauteil (Produktart)</i>	Model/Type <i>Modell/Typ</i>	Manufacturer <i>Hersteller</i>
NG-5123AT0378	Flat sealing materials on synthetic fiber basis	novatec® PREMIUM XP/novatec® PREMIUM XP	Frenzelit GmbH

Hints of Utilization / Remarks
Verwendungshinweise / Bemerkungen

application area: screw connections for 2-pipe gas meters according to DIN 3376-1 and screw connections for governors and 1-pipe gas meters according to DIN 3376-1, DIN 3376-2, EN 10241, EN 10242 as well as flanges for governors and gas meters according to DIN 3376-2, DIN EN 1092-1, DIN EN 1092-2